

ADDENDUM 1

Project Name: 2024 Misc. Water

Release Date: Tuesday, November 12, 2024 4:00 p.m.

Original Bid Opening Date: Wednesday, November 13, 2024 2:00 p.m.

Revised Bid Opening Date: Friday, November 15, 2024 10:00 a.m.

Information To Bidders:

The contract Documents for the above titled project is hereby amended as follows:

Revised Bid Opening Date:

- The bid opening date is being moved to **Friday, November 15, 2024 at 10:00 a.m.**

Clarifications:

The following is being provided as answers to questions that have been asked so far:

- The installation of all watermains (2" and 4") is intended to be by the horizontal directional drilling method. Service lines (1") may be open-cut or bored.
- Service saddles shall be ROMAC Industries Style 202N-H, or approved equal, designed to compensate for pipe contraction due to temperature and pressure changes.
- All pipe may be SDR-9. SDR-7 will not be required.

ROGERS WATER UTILITIES

By: Stephen Ponder, PE